



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

C.I.M. Industries Inc
375 University Avenue
Westwood, MA 02090

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: CIM 800 and CIM ECO 1000 Waterproofing Systems

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA 24-0321.11 and consists of pages 1 through 5.
The submitted documentation was reviewed by Jorge L. Acebo.

10/02/25



NOA No.: 25-0402.03
Expiration Date: 08/15/29
Approval Date: 10/02/25
Page 1 of 5

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Waterproofing
Deck Type: Concrete
Material: Polyurethane
Maximum Design Pressure: N/A

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
CIM 800	5 gallons	ASTM C836	Two component, liquid applied urethane coating for waterproofing.
CIM ECO 1000	5 gallons	ASTM C836	Two component, liquid applied urethane coating for waterproofing.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Specification</u>	<u>Date</u>
NEMO ETC, LLC	4p-CIM-23-SSLAP-01.A	ASTM C836	03/07/24
	4p-CIM-SSLAP-001.A	ASTM C836	07/15/25



APPROVED APPLICATIONS:

- Deck Type 3** Concrete Decks, Roof Plaza Decks, Parking Decks
- Deck Description:** Min. 3000 psi, dual slab construction (roof plaza and parking decks)
- System Types F(1):** CIM 800
- Substrate Preparation:** All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of unapproved curing compounds, from release agents and other surface contaminants. Surface preparation and repair requirements should comply with the manufacturer published guidelines.
- Primer:** Apply onto prepared concrete surface CIM EMT Epoxy Primer at a rate of 100 sq. ft./gal. or CIM ECO Epoxy Primer at a rate of 200-225 sq. ft./gal. Apply using squeegee, brush, or roller resulting in a minimum coating thickness of 15-20 mils or 5-10 mils, respectively. Allow primer to cure at least 4 hours at 70°F.
- Base Coat:** N/A
- Top Coat:** Apply onto primer CIM 800 with roller, squeegee, trowel, or spray equipment (requires large diameter hose and air supplied mastic gun). Refer to CIM 800 Coverage Chart for coverage rates.
- Recoating:** CIM 800 may be recoated in 1 hour and must be recoated soon after the coating no longer comes off on polyethylene (typically within 4 hours of mixing). If the coating has cured longer than this time, the surface must be severely abraded using surface grinder or other mechanical means and be free of dust and debris.
- Integrity Test:** Required, and shall be performed in accordance with ASTM D 5957 by an approved lab. Water may be maintained for a period longer than 24 hours if required.
- Inspection:** Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.
- Surfacing:** Structural Concrete Slab, minimum 3000 psi shall be designed to comply with applicable Building Code requirements.
- Maximum Design Pressure:** N/A



Deck Type 3	Concrete Decks, Roof Plaza Decks, Parking Decks
Deck Description:	Min. 3000 psi, dual slab construction (roof plaza and parking decks)
System Types F(2):	CIM ECO 1000
Substrate Preparation:	All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of unapproved curing compounds, from release agents and other surface contaminants. Surface preparation and repair requirements should comply with the manufacturer published guidelines.
Primer:	Apply onto prepared concrete surface CIM EMT Epoxy Primer at a rate of 100 sq. ft./gal. or CIM ECO Epoxy Primer at a rate of 200-225 sq. ft./gal. Apply using squeegee, brush, or roller resulting in a minimum coating thickness of 15-20 mils or 5-10 mils, respectively. Allow primer to cure at least 4 hours at 70°F.
Base Coat:	N/A
Top Coat:	Apply onto primer CIM ECO 1000 with roller, squeegee, trowel, or spray equipment (requires large diameter hose and air supplied mastic gun or plural component spray equipment). Refer to CIM ECO 1000 Coverage Chart for coverage rates.
Recoating:	CIM ECO 1000 may be recoated in 1 hour and must be recoated soon after the coating no longer comes off on polyethylene (typically within 4 hours of mixing). If the liner has cured longer than this time, the surface must be severely abraded using surface grinder or other mechanical means and be free of dust and debris. For immersion conditions, all coats shall be applied within 4 hours of each other, except joint lines.
Integrity Test:	Required, and shall be performed in accordance with ASTM D 5957 by an approved lab. Water may be maintained for a period longer than 24 hours if required.
Inspection:	Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.
Surfacing:	Structural Concrete Slab, minimum 3000 psi shall be designed to comply with applicable Building Code requirements.
Maximum Design Pressure:	N/A



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. A copy of the integrity test report described herein in accordance with ASTM D5957 shall be provided to the Building Official for review at time of final inspection.
3. Contractor shall submit to the Building Official for review the system specifications and details. Submission of these documents, as well as the proper application and installation of all materials shall be the sole responsibility of the contractor.
4. All work shall be performed by a Contractor licensed to do roofing/waterproofing. Contractor shall be familiar with the details and shall be approved by C.I.M. Industries Inc.
5. A non-skid surfacing is required for all pedestrian areas, plaza decks or balconies.
6. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and the wind load requirements of applicable Building Code.
7. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
8. C.I.M. Industries Inc, CIM 800 and CIM ECO 1000 shall not be installed without consultation with C.I.M. Industries Inc, if ambient or surface temperature is below 0°F. Do not apply to wet or frozen concrete surface.
9. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

